

April 22, 2024

IDEA PUBLIC SCHOOLS Donna Building Envelope

GMS ARCHITECTS  
BROWNSVILLE, TEXAS 78526  
(956) 546-0110

**ADDENDUM NO.**

*content. All aspects of the specifications and drawings not covered herein shall remain the same.*

*The General Conditions and the Special Conditions of the specifications shall govern all parts of the work and apply in full force to this addendum.*

**B. SCOPE**

**I. CLARIFICATION:**

Proposals must be submitted by sending a hard copy to:

IDEA Public Schools  
Attn. Purchasing Department  
2115 West Pike Blvd  
Weslaco, TX 78596

Proposals sent by mail must be in a sealed envelope marked with the RFP Number and Title and include:

- a) One (1) clearly identified hard copy ORIGINAL of the Proposal.
- b) One (1) copy of the Proposal on FLASH DRIVES, marked with the

c)

**Note: Faxed or emailed Proposals will not be accepted.**

The proposal will be read aloud via Microsoft Teams at the link below:

[Join the meeting now](#)

Meeting ID: 222 119 618 202

Passcode: y8ZDrX

Estimated Budget: \$ 2,500,000.00.

Anticipated Start Date: May 27,2024

Attached is Sign-In Sheet from Pre-Bid Conference on 4/17/2024.

**II. SPECIFICATIONS:**

Section 004100 Proposal Form: **New Bid Form**

**III. PLANS:**

N/A

#### **IV. QUESTION AND ANSWERS (Argio Roofing)**

##### Roof:

- Q: On Page A2.01: Scope of work, states to remove membrane to recover board. The specifications calls to for new tapered insulation over the metal deck: Are we removing the entire roof system to deck or doing a recovery roof system?  
A: Contractor to remove entire existing roof system to deck.
  
- Q: On page A2.01: the metal roof at entrance, are we doing any wok on that metal roof?  
A: No work to be performed on the arched metal roof.

Building Elevations:





DECLARATION

DELAY COST

EXECUTION OF CONTRACT

RECEIPT OF ADDENDA

† We have reviewed the A101 and A201 and the supplementals to the A101 and A201 and take no exceptions.